

NOTES:

- 1. Seal all openings in the vault with non-shrink grout, or Link-Seal.
- 2. 2 1 cu.yd. thrust blocks outside vault, w/ pipe clamp type Joint Restraints, entering and exiting the vault.
- 3. The meter size shall match the service size, or one size smaller.
- 4. A 2" test port shall be installed, vertically, with a 2" double strap tapping saddle, and a 2" Corp Stop (fip x fip w/ brass cap). The test port must be as close to the downstream GV as possible.
- Full mainline size GV's shall be set outside of the vault. You will need to reduce from full mainline size to the meter size, and use DI Spools entering the vault from the reducers. ALL REDUCERS MUST BE OUTSIDE OF VAULT
- 6. The meter must have no fittings within a length of 5 times the diameter of the pipe, upstream, and 3 times the diameter of the pipe, downstream. With the exception of the test port.

